



Certificate of Analysis

For: Environmental Remediation and Management
20-10 Maple Avenue
Fairlawn, NJ 07410
Attn: Willie Morales

Water Quality Supervisor: *Stephen Haflich* 18-Jul-16

Client Sample ID: MM01 A Near 113 Lab Sample ID: 16071506-01
Site: Collection Date: 7/15/2016 10:25 AM

Analyte	Method	Sample Result	Report Limit	Analyst	Anal. Date
Lead	EPA 200.8	0.97 ppb	0.5	JenB	7/18/2016

Client Sample ID: MM01 F Near 113 Lab Sample ID: 16071506-02
Site: Collection Date: 7/15/2016 10:27 AM

Analyte	Method	Sample Result	Report Limit	Analyst	Anal. Date
Lead	EPA 200.8	88.98 ppb	0.5	JenB	7/18/2016

Client Sample ID: MM02 A Near 121 Lab Sample ID: 16071506-03
Site: Collection Date: 7/15/2016 10:28 AM

Analyte	Method	Sample Result	Report Limit	Analyst	Anal. Date
Lead	EPA 200.8	1.09 ppb	0.5	JenB	7/18/2016

Client Sample ID: MM02 F Near 121 Lab Sample ID: 16071506-04
Site: Collection Date: 7/15/2016 10:30 AM

Analyte	Method	Sample Result	Report Limit	Analyst	Anal. Date
Lead	EPA 200.8	0.52 ppb	0.5	JenB	7/18/2016

Client Sample ID: MM03 A Near 217 Lab Sample ID: 16071506-05
Site: Collection Date: 7/15/2016 10:32 AM

Analyte	Method	Sample Result	Report Limit	Analyst	Anal. Date
Lead	EPA 200.8	5.81 ppb	0.5	JenB	7/18/2016

Client Sample ID: MM03 F Near 217 Lab Sample ID: 16071506-06
Site: Collection Date: 7/15/2016 10:36 AM

Analyte	Method	Sample Result	Report Limit	Analyst	Anal. Date
Lead	EPA 200.8	1.08 ppb	0.5	JenB	7/18/2016

Client Sample ID: MM04 A Next to Gym

Lab Sample ID: 16071506-07

Site:

Collection Date: 7/15/2016 10:38 AM

Analyte	Method	Sample Result	Report Limit	Analyst	Anal. Date
Lead	EPA 200.8	1.32 ppb	0.5	JenB	7/18/2016

Client Sample ID: MM04 F Next to Gym

Lab Sample ID: 16071506-08

Site:

Collection Date: 7/15/2016 10:42 AM

Analyte	Method	Sample Result	Report Limit	Analyst	Anal. Date
Lead	EPA 200.8	2.38 ppb	0.5	JenB	7/18/2016

Client Sample ID: MM05 A Kitchen

Lab Sample ID: 16071506-09

Site:

Collection Date: 7/15/2016 10:45 AM

Analyte	Method	Sample Result	Report Limit	Analyst	Anal. Date
Lead	EPA 200.8	2.37 ppb	0.5	JenB	7/18/2016

Client Sample ID: MM05 F Kitchen

Lab Sample ID: 16071506-10

Site:

Collection Date: 7/15/2016 10:50 AM

Analyte	Method	Sample Result	Report Limit	Analyst	Anal. Date
Lead	EPA 200.8	6.82 ppb	0.5	JenB	7/18/2016

NA = not analyzed

CHAIN OF CUSTODY / ANALYSIS REQUEST

Name (for report and invoice)		Samplers Name		E2 Reporting		LAB USE ONLY	
Guillermo M. Morales		Phone: 973-949-3525		Check Box <input type="checkbox"/> if E2 reporting is requested		Lab Log Number	
ER&M, Inc.		E-Mail: ERMNJ@aol.com		Provide PWSID Number, Water Facility State Code, & Sample Point ID, where applicable		Cooler Temperature °C	
Address				Analysis requested (enter "X" below to indicate request)			
City	State	Zip Code	District	Preservative used	Preservative used	Preservative used	Preservative used
Fair Lawn, NJ	NJ	07410	Fair Lawn BOE				
Turnaround Request:				Lead			
ASAP	<input checked="" type="checkbox"/> Standard	<input type="checkbox"/>		X			
Sample Identification				Date Collected	Time Collected	Matrix	No. of Containers
MM01A	Near 113	-11-	7/15/16	1025	D		
MM01F	-11-	-11-		1027			
MM02A	Near 121			1028			
MM02F	Near 121			1030			
MM03A	Near 217			1032			
MM03F	-11-	-11-		1036			
MM04A	Next to Gym			1038			
MM04F	-11-	-11-		1042			
MM05A	Kitchen			1045			
MM05F	Kitchen			1050			

Social Institutions: X
 Company: ER&M
 Date/Time: 7/15/16 12:53
 Received by: [Signature]
 Company: Water Mains Filtered (WNT)
 Date/Time: 7/15/16 12:53
 Received by: [Signature]
 Company: [Signature]